# TECHNICAL GUIDE AND PARTS LIST

CAL. V267A

ANALOGUE QUARTZ


#### CONTENTS


ı.	SPECIFICATIONS		
Ħ,	DISASSEMBLING, REASSEMBLING AND LUBRICATING 2 ~		
III.	CHECKING AND ADJUSTMENT		
	1. Structure of circuit block		
	2. Procedure for checking and adjustment		
EV/	PARTSIIST		


## I. SPECIFICATIONS


Cal. No.		V267A	
Indication syst	em	Three hands  Step motor  Date Date quick resetting device Second setting device Electronic reset switch	
Driving system	The state of the s		
Additional me	chanis <b>m</b>		
Los s/gain		Monthly rate: less than 20 seconds at normal temperature range	
	Size of main plate	φ20.7 mm (6H – 12H 19.5 mm, 3H – 9H 15.3 mm)	
Movement .	Casing diameter	φ20.0 mm	
size	Height	2.7 mm	
Regulation system			
Quartz Tester measuring gate		10-second gate	
Battery		SEIKO (SEIZAIKEN) TR621SW, Maxell SR621SW, SONY EVEREADY 364 Voltage: 1.55V	
Battery life		Approx 2 years for SEIKO (SEIZAIKEN) TR621SW Approx 1.5 years for MAXELL SR621SW and SONY EVEREADY 364	
Jewels		1 jewel	

## II. DISASSEMBLING, REASSEMBLING AND LUBRICATING










### III. CHECKING AND ADJUSTMENT



#### 2. Procedure for checking and adjustment

- This section only gives the checking and adjustment procedure which is exclusive for this watch.
   For the normal checking and adjustment, refer to the "TECHNICAL GUIDE GENERAL INSTRUCTION, Analogue Quartz".
- The page numbers in the item correspond to those in the "TECHNICAL GUIDE GENERAL INSTRUCTION, Analogue Quartz".

## **OUTPUT SIGNAL p.6** 1. Use the Quartz Tester. 2. Turn the measuring time selection switch to the "10-second" gate. Output signal: Normal No output signal: Defective Checking should be made with the crown set to normal position. **BATTERY VOLTAGE** Use the SEIKO Digital Multi Tester S-840A Result: 1.57V or more: Normal Range to be used: DC V Less than 1.57V: Defective NOTE: Replace the battery. Before measuring, short circuit the probes and confirm that the tester reads AUTO 00.0 mV or AUTO 00.1 mV. **BATTERY CONDUCTIVITY p.9** Check the conductivity between battery and battery connection (-), etc to see if the battery voltage is correctly applied to the circuit. CIRCUIT BLOCK CONDUCTIVITY p.9 Check the output terminal and pattern section contamination in the circuit block and check if the circuit is broken or short.

#### COIL BLOCK p.10

Check the coil block for broken wire and short circuit using the SEIKO Digital Multi Tester S-840A.

Range to be used:  $\Omega$ 

- Before measuring, short circuit the probes and check to see if the tester sounds and reads from AUTO 00.2 $\Omega$  to AUTO 00.4 $\Omega$ . The actual resistance can be obtained by subtracting the initial value (00.2 - 00.4) from the measured value.
- When measuring, take care not to break the coil block leads.

 $2.4 \sim 2.8 \text{ k}\Omega$ : Normal Less than 2.4 k $\Omega$  (Short circuit):

Defective

More than 2.8 k $\Omega$  (Broken wire): Defective

Replace the coil block

#### FRONT GEAR TRAIN MECHANISM p.11

Check the front gear train mechanism for play of rotor and wheels and pinions, mis-installation, dust, lint, foreign matter, lubrication, etc.


#### BACK GEAR TRAIN MECHANISM p.11

Check the back gear train mechanism for lubrication leadkage, play, dust, lint,

#### RESET CONDITION

With the movement installed, check that the reset condition is normal.

- 1. Check the clearance between the train wheel setting lever and fourth wheel and pinion.
- (1) Check the clearance with the crown at normal and first click position.



Result:

Clearance: Normal No clearance: Defective

Replace the train wheel setting

lever.

Defective

(2) Check the clearance with the crown at second click position.



Defective

Result:

No clearance: Normal Clearance: Defective

Replace the train wheel setting

lever.

2. Check the output signal with the battery installed.

- (1) Check the output signal with the crown at normal and first click posi-
- (2) Check the output signal with the crown at second click position.

Result:

Output signal: Normal No output signal: Defective

Replace the reset lever.

Result:

No output signal: Normal Output signal: Defective Replace the reset lever.

#### ACCURACY p.13

Check accuracy using Quartz Tester and an electromagnetic microphone (DM-1).

#### NOTE:

Check accuracy with the crown at normal position.


Monthly rate (at normal temperature range)

Less than 20 seconds: Normal More than 20 seconds: Defective

Replace the circuit block.

#### **CURRENT CONSUMPTION**

1. Use the SEIKO Digital Multi-Tester S-840A (with Multi Adaptor MA-40)



#### NOTE:


Press the reset switch to read 00.0  $\mu A$  and measure the current consump-

Red probe -- Winding stem holder

Black probe → Battery connection (-)

When measuring the current consumption under the incandescent lamp, cover the movement with black cloth. Otherwise the measured value sometimes becomes higher than the actual value.

2. Check the current consumption of the circuit block.



Result:

1.2 µA or less: Normal More than 1.2 µA: Defective Proceed to 2

Result:

0.3 µA or less: Circuit block is nor-

Check the gear train mechan-

More than 0.3 µA: Circuit block is defective.

Replace the circuit block.

## IV. PARTS LIST

PARTS NO.	PARTS NAME	PARTS NO.	PARTS NAME	
125 234	Train wheel bridge	* 801 328	Date dial	
195 230	Calendar plate	* 801 329	Date dial	
197 233	Winding stem cock with battery con-	* 801 336	Date dial	
	nection ()	802 230	Date driving wheel	
231 233	Third wheel & pinion	808 231	Date dial guard	
* 241 231	Fourth wheel & pinion	884 147	Holding ring for dial	
• 241 234	Fourth wheel & pinion	4000 220	Circuit block	
261 233	Minute wheel	4002 240	Coil block	
1 270 051	Center minute wheel	4146 236	Step rotor	
• 270 052	Center minute wheel	4225 233	Battery clamp	
* 271 066	Hour wheel	4239 233	Rotor stator	
* 271 067	Hour wheel	4408 235	Winding stem holder support	
281 233	Setting wheel	4455 233	Reset lever	
282 233	Clutch wheel	011 334	Upper hole jewel for step rotor	
* 354 232	Winding stem	012 015	Case screw	
* (354 233)	(Winding stem)	012 019	Circuit block screw	
* (354 234)	(Winding stem)	012 020	Train wheel bridge screw	
387 234	Minute wheel bridge	012 023	Battery clamp screw	
391 230	Train wheel setting lever	012 825	Winding stem holder screw	
426 230	Train wheel bridge support	012 826	Date dial guard screw	
491 233	Dial washer	032 032	Case screw pin	
556 231	Date finger	033 019	Reset pin	
701 236	Fifth wheel & pinion	033 050	Eccentric dial pin	
* 735 012	Winding stem holder	. SEIKO (SEIZAIKEN)	Battery	
766 230	Intermediate minute wheel	TR621SW		
* 801 136	Date dial	MAXELL SR621SW	Battery	
* 801 137	Date dial	SONY EVEREADY	Battery	
* 801 327	Date dial	364	•	

#### Remarks

#### Combination:

*Type	Fourth wheel & pinion	Center minute wheel	Hour wheel
L	241 231	270 052	271 067
M	241 234	270 051	271 066

\*abbriveation L.....Long type (Movement type) M......Standard type

\* Date dial

Crown Position	Calendar frame Position	Specifications
3 o'clock	3 o'clock	Black figures on white background
3 o'clock	6 o'clock	Black figures on white background
3 o'clock	3 o'clock	White figures on black background
3 o'clock	3 o'clock	Black figures on gold background
3 o'clock	6 o'clock	White figures on black background
3 o'clock	6 o'clock	Black figures on gold background
	Position 3 o'clock 3 o'clock 3 o'clock 3 o'clock 3 o'clock	Position Position  3 o'clock 3 o'clock  3 o'clock 6 o'clock  3 o'clock 3 o'clock  3 o'clock 6 o'clock  3 o'clock 6 o'clock

<sup>\*</sup> Fourth wheel & pinion, Center minute wheel, Hour wheel There are two different types as specified below.

<sup>\*</sup> Winding stem holder for Pulsar Watches....735018 (Pulsar marking)

<sup>\*</sup> Winding stem
The type of winding stem is determined based on the design of case.