TECHNICAL GUIDE AND PARTS LIST

CAL. Y580A

ANALOGUE QUARTZ

FOREWORD

In Cal. Y580A, many plastic parts (engineering plastic) are used, compared with the current models.


Compared with the current plastic, engineering plastic has superb strength, is solvent and heat proof. It has been developed as a material for watch components as a substitute for metal.

However, special care should be taken when checking or servicing the watch. Especially, take care for handling and cleaning the parts.

For details, refer to the corresponding sections in this Technical Guide.

Notes on fitting the hands

When fitting the hands, support the train wheel bridge with a flat solid material (stainless steel, glass, etc.) and press in the hands. Never use a universal movement holder which does not support the train wheel bridge. When fitting the hands, remove the battery.




CONTENTS

| I. | SPECIFICATIONS | 1 | |
|------------|--|---|--|
| 11. | STRUCTURE OF CIRCUIT BLOCK | 1 | |
| 111, | LIST OF SCREWS USED | 1 | |
| IV. | STEP MOTOR COMPENSATION DRIVING PULSE SYSTEM | 2 | |
| V. | DISASSEMBLING, REASSEMBLING AND LUBRICATING | 3 | |
| VI. | CHECKING AND ADJUSTMENT | | |
| | A. Check output signal | 5 | |
| | B. Check battery voltage | 5 | |
| | How to repair the movement when battery electrolyte leakage occurs | 5 | |
| | C. Check battery conductivity | 5 | |
| | D. Check circuit block conductivity | 5 | |
| | E. Check coil block | 6 | |
| | F. Check gear train mechanism | 6 | |
| | G. Check accuracy | 6 | |
| | Check current consumption | 6 | |
| VII | PARTS LIST | 7 | |
| | | | |

I. SPECIFICATIONS

| tem | Cal. No. | Y580 A | |
|----------------------------|----------------------------|--|--|
| Time indication Loss/gain | | 2-hand | |
| | | Monthly rate: Less than 20 seconds at normal temperature range | |
| | Size of main plate | 13.0 mm (3H - 9H) × 15.55 mm (6H - 12H) | |
| Movement size | Casing diameter | 13.0 mm x 15.15 mm | |
| 5126 | Height (including battery) | 2,59 mm (2.65 mm) | |
| Regulation system | | None | |
| Measuring gate | | 10-second gate | |
| Battery | | SEIZAIKEN TR616SW, MAXELL SR616SW Battery life: Approx. 3 years Voltage: 1.55V | |
| Jewels | | 0 jewels (2 jewels in some models) | |

II. STRUCTURE OF CIRCUIT BLOCK



III. LIST OF SCREWS USED

All screws used in Y580A are the same.

Code No. 022247

| Train wheel bridge screw | 1 | |
|---------------------------|---|---|
| Circuit block cover screw | 3 |) |
| Cail block corner | 4 | |




IV. STEP MOTOR COMPENSATION DRIVING PULSE SYSTEM

(Special motor drive circuit with a low current consumption)

- With the current quartz circuit, the pulse width supplied from the electric circuit to step motor is constant (Fig.1).
- In Cal. Y580A, the drive pulse width changes according to the load required to drive the step motor. In the normal conditions, the circuit supplies the minimum power to drive the hands. If the extra load is applied (at a low ambient temperature), an enough pulse is supplied to overcome the load (Fig. 2).
- As the minimum pulse width is required to drive the step rotor in normal conditions, the minimum power consumption results.

(For checking the current consumption, refer to page 6.)








Fig. 2

4

V. DISASSEMBLING, REASSEMBLING AND LUBRICATING





VI. CHECKING AND ADJUSTMENT

- This section describes the adjustment and maintenance procedures required for this watch.
- For other adjustment and maintenance, refer to the "TECHNICAL GUIDE GENERAL INSTRUCTION, An-
- alogue Quartz"
- The page numbers in this section correspond to those in the "TECHNICAL GUIDE GENERAL IN-STRUCTION, Analogue Quartz".

Δ

OUTPUT SIGNAL p.6

Use the quartz tester to check the output signal of every 20 seconds with the crown in the normal position.

Result:

Output signal → Normal
No output signal → Defective



BATTERY VOLTAGE p.7

Use Digital Multi Tester S-840A. Range to be used: DCV

Result:

1.5 V or more → Normal Less than 1.5 V → Replace the battery

NOTE: Before measuring, short circuit the probes and confirm that the display shows "AUTO 00.0 mV" or "AUTO 00.1 mV."

HOW TO REPAIR THE MOVEMENT WHEN BATTERY ELECTROLYTE/LEAKAGE OCCURS p.8




BATTERY CONDUCTIVITY p.9

Check to see if the battery current flow to the circuit is normal.



CIRCUIT BLOCK CONDUCTIVITY p.9


Remove the circuit block and check the conductivity at the points indicated by the arrows with a microscope.





COIL BLOCK p.10

1. Check for any contamination on the coil lead terminal.



2. Check the coil block for broken wire or short circuit. Use Digital multi-tester S-840A. Range to be used: Ω

Note: Before measuring, short circuit the probes and confirm that the beep signal sounds and the display shows "AUTO 00.2 Ω " or "AUTO 00.4 Ω ".

The resistance can be obtained by subtracting the measured value from the initial value (00.2 – 00.4).

Result:

 $2.0 - 2.5 \text{ k}\Omega \rightarrow \text{Normal}$

Less than 2.0 k Ω \rightarrow Defective (short-circuit)

More than 2.5 kΩ → Defective (Broken coil wire)



GEAR TRAIN MECHANISM p.11

ACCURACY p.13

Use the Quartz Tester with the electromagnetic microphone

Result:

Monthly rate:

Less than 20 seconds → Normal

More than 20 seconds → Defective


Replace the circuit block

CURRENT CONSUMPTION

- If frequent battery change is required, a current consumption test is recommended.
- Measure the current consumption with the Digital Multi Tester S-840 A and Multi Adapter MA-40.

Pasult:

Less than 2.0 μA → Normal 2.0 μA or more → Defective



Note:

Before measuring, press the reset switch to display "00.0 μ A".

Red probe (+) ... Battery connection ⊖

Black probe (-) . . . Battery surface ⊖

When measuring that the current consumption under the incandescent lamp, cover the movement with black cloth. Otherwise the measured value sometimes becomes higher than the actual value.

VII. PARTS LIST

| Cal. Y580 A | | | | | | |
|-------------|------------------------------|--|-----------------------------|--|--|--|
| PARTS NO. | PART NAME | PARTS NO. | PARTS NAME | | | |
| 125 902 | Train wheel bridge | 4457 832 | Circuit block cover | | | |
| 221 902 | Center wheel & pinion | 022 247 | Train wheel bridge screw | | | |
| 231 705 | Third wheel & pinion | 022 247 | Circuit block cover screw | | | |
| 261 902 | Minute wheel | 022 247 | Coil block screw | | | |
| 271 902 | Hour wheel | 027 166 | Tube for train wheel bridg | | | |
| 354 902 | Winding stem | 027 166 | Tube for circuit block cove | | | |
| 491 546 | Diel washer | | screw (c) | | | |
| 711 902 | Guide plate for winding stem | 027 167 | Tube for circuit block cove | | | |
| 4001 832 | Circuit block | L Laboratoria | screw (a) | | | |
| 4002 832 | Coil block | 027 168 | Tube for circuit block cove | | | |
| 4146 833 | Step rotor | Na de constante de la constant | screw (b) | | | |
| 4239 832 | Rotor stator | 027 169 | Tube for coil block screw | | | |
| 4270 832 | Battery connection (-) | SEIZAIKEN TR616SW | Battery | | | |
| 4271 832 | Battery connection (+) | MAXELL SR616SW | σαιτοιγ | | | |