# PARTS CATALOGUE/TECHNICAL GUIDE

# Cal. W306A

#### [SPECIFICATIONS]

	Cal. No.	W306A		
ltem	The state of the s			
Module				
		10:0859.		
		(x 1.0)		
	Outside diameter	φ27,4mm		
Module size	Height	4.8mm		
Display medic	ım	Nematic Liquid Crystal (Field Effect Mode)		
Liquid crystal driving system		1/3 multiplex driving system		
Display system		<ul> <li>Time/calendar display (12- or 24-hour indication)</li> <li>Time/calendar setting display</li> <li>Alarm setting display (12- or 24-hour indication)</li> <li>Stopwatch display (Up to 60 minutes in 1/100 seconds)</li> </ul>		
Additional mechanism		Multi alarm Hourly time signal All segments light-up system Instant calendar setting device Automatic return system		
Loss/gain		Monthly rate at normal temperature range: less than 20 seconds		
Regulation system		Nil		
Measuring gate by quartz tester		Any gate can be used.		
Battery		SEIKO CR2016, Maxell CR2016, Sanyo CR2016, Matsushita CR2016, EVEREADY CR2016 Battery life is approximately 5 years. Voltage: 3.0V		

HATTORI SEIKO CO., LTD.


# PARTS CATALOGUE

al. W306A

Reasser		1) ~ (15) 15) ~ (1) Oil quantity ,000 c.s.	quantity
	1 Case back ————————————————————————————————————		
	2) Case back gasket	Contract of the second of the	
	3) Module		
	(4) Case middle		
			Button (3 pcs.)

### **PARTS CATALOGUE**

#### Cal. W306A



## **PARTS CATALOGUE**

Cal. W306A

#### Remarks:

(14) Liquid crystal panel 4510 537 (Silver) 4510 538 (Gold)

Be sure to check that combination of the colors of the panel cover and liquid crystal panel is made properly according to the "Casing Parts Catalogue".

Other parts


Piezoelectric element 4589 650


# **TECHNICAL GUIDE**

Cal. W306A

- The explanation here is only for the particular points of Cal. W306A. For detailed checking and adjustment, refer to the "TECHNICAL GUIDE AND PARTS LIST CAL. W309A".
- For the normal repairing, checking and measuring procedures, refer to the "TECHNICAL GUIDE, GENERAL INSTRUCTIONS".

#### I. STRUCTURE OF THE CIRCUIT BLOCK






### **TECHNICAL GUIDE**

#### Cal. W306A


# II. RELATIONSHIP BETWEEN THE SEGMENT (LIQUID CRYSTAL PANEL ELECTRODE) AND THE C-MOS-LSI OUTPUT TERMINAL

#### • Designation of the segment



• Segment (Liquid crystal panel electrodes)

C-MOS-LSI output terminal



### **TECHNICAL GUIDE**

Cal. W306A

#### III. REMARKS ON INSTALLING THE BATTERY

After the battery is replaced with a new one, or after the battery is re-installed following the repairing procedures, be sure to short-circuit the system reset pattern and battery (+) surface with conductive tweezers as indicated in the illustration below to reset the circuit. The watch will be set in the following conditions, so press the buttons to set the TIME/CALENDAR.

Display : TIME display

Alarm/hourly time signal : Disengaged

Multi alarm : Disengaged
Time display : 12:00'00" A.M.

Calendar display : January 1, Sunday

Alarm time : 12:00 A.M.
Stopwatch : Reset to "00"

System reset pattern

Buzzer lead terminal

Battery

W306A

JAPAN

Movement secure dowel

(4 pcs.)

Insulator for battery


#### IV. REMARKS ON DISASSEMBLING AND REASSEMBLING

(2) Case back gasket

Apply silicone oil to the case back gasket.


- (4) Case middle
- Notes on replacing the buttons
- 1) Do not remove the buttons except when they need to be replaced with new ones for repair.
- 2) When removing the buttons, be sure to replace them with new ones.
- 3) When replacing the buttons with new ones, he sure to apply silicone oil to the new buttons.
- (5) Battery clamp
- How to remove

Release the battery clamp from the circuit block cover by inserting the tip of tweezers as shown in the illustration at right,



#### How to install


Set "A" portion of the battery clamp to the circuit block cover, checking that there is no clearance between them, and then hook the opposite portion to the protrusion of the circuit block cover as shown in the illustration at right.



(7) Circuit block cover

#### How to remove


Pry up the circuit block cover from the liquid crystal panel at the four hooking portions ("B" portions) with tweezers as shown in the illustration at right.



(9) Buzzer lead terminal

#### How to install

Put the tip of the buzzer lead terminal between the two protrusions of the liquid crystal panel frame as indicated in the illustration at right.



#### V. VALUE CHECKING

Coil block resistance

 $50\Omega \sim 90\Omega$ 

Current consumption

For the whole of the module:

less than 1.7μA

For the circuit block alone :

less than 1.5µA